



ENVIRONMENTAL LABORATORY

(UNIT OF MINERAL ENGINEERING SERVICES)

Accredited by NABL (TC-6172) Recognised by BIS, FSSAI, ISO:45001:2018 Certified Laboratory
MoEFCC(CPCB) under E(P) Act 1986 recognition valid upto 23.05.2025



TEST REPORT

Page No. 1/1

Issued To : M/s.KRISHNA ELECTRICALS
Chennai.

Report No. : PM002523092
Issue Date : 11/05/2024
Your ref. : LETTER
Ref.Date : 11/05/2024

Particulars of sample received : Copper Strip-1 No (25 x 6mm)
Date of sample receipt : 01/05/2024
Lab Code : PM/23/09/2-0025
Sample quantity : 9gms
Date of Commencement of testing : 11/05/2024
Date of Completion of testing : 11/05/2024

TEST RESULTS

Sl. No	Test Parameters	Results	Test Methods
1	Copper, %	99.45	SOP/C/M/01 issue No.1 issue date:05/09/2022
2	Lead, %	0.031	SOP/C/M/01 issue No.1 issue date:05/09/2022
3	Bismuth, %	0.0026	SOP/C/M/01 issue No.1 issue date:05/09/2022

END OF REPORT

ARSHIYA KOUSAR
Dy. T.M. - Chemical
Authorised Signatory

948, 2nd Cross, St. Thomas Town Post, Kammanahalli, Bangalore - 560 084.
Phone : 080-25432969 Tel/fax : 25432968. E-mail : mesbng@gmail.com, www.envtest.in